

Headquarters
United States Forces Korea
Unit #15237
APO AP 96205-5237

United States Forces Korea
Pamphlet 200-1
C1

USFK Pamphlet No. 200-1
Change No. 1

27 July 2010

Environmental Quality

ENVIRONMENTAL GOVERNING STANDARDS (EGS)

FOR THE COMMANDING GENERAL:

JOSEPH F. FIL, JR.
Lieutenant General, USA
Chief of staff

OFFICIAL:



GARRIE BARNES
Chief of Publications and
Records Management

Summary of Change.

USFK Pamphlet 200-1, 20 October 2004, is revalidated with the following change:

1. Add page 201, paragraph 19-3c(9).
2. Post these changes IAW DA Pam 25-40.
3. File this change sheet in front of the publication.

Page 201, paragraph 19-3, Criteria. Insert new paragraph 19-3c(9) as follows:

19-3c.(9) Leak detection systems will be evaluated.

(a) Systems using secondary containment as part of the required leak detection method will, at least annually, evaluate the secondary containment to ensure tightness.

(b) Systems or parts of systems using other approved leak detection methods will conduct annual soil testing at four locations within the UST excavation. Soils tested shall be approximately 1.5 meters below the deepest part of the UST. Underground pipelines will be tested at 10 meter increments at a depth of 1.5 meters below the line. If contamination is identified, provisions of DoDI 4715.8 and USFK Reg 200-1 will apply.